SAVANT

60 Amp Relay Companion Module with Current Transformer (Supports Eaton CH Load Centers) Quick Reference and Installation Guide


Box Contents

- (1) 240VAC (2 Pole) Relay Companion Module (Eaton CH)
 - GPM-CP1R60240-21 w/Plug-on Neutral -or-
 - GPM-C1R60240-21 w/Pigtail
- (1) Product Information and Regulatory Insert (009-1950)
- (1) Quick Reference and Installation Guide (this document)

Specifications

Location Indoor Use Only Dimensions and Weights (net) Length Width Height Weight Module 4.98 inch (12.65 cm) 2.91 inch (8.62 cm) 1.0 lbs (4.45 kg) Shipping 7.32 inch (18.6 cm) 6.18 inch (15.7 cm) 3.15 inch (8.00 cm) 1.25 lbs. (57 kg) Power Input Power (powers the module) 120V AC (+/- 10%) @ 60Hz, 0.1A (max) Input Power (from external source) 240V AC @ max load power Load Power 14400VA max (240VAC 60A resistive load / 3HP max) Features of Automatic Action Type 1.B action Standards Wireless Bluetooth Low Energy (BLE) - 2.4 GHz radio frequency Regulatory	Specificat	10113								
Humidity	Environme	ntal								
Dimensions and Weights (net)	Temperature	e 32°	to 104° F (0°	to 40° C)						
Dimensions and Weights (net)	Humidity	5%	5% to 85% Relative Humidity (non-condensing)							
Length Width Height Weight	Location	Location Indoor Use Only								
Module 4.98 inch (12.65 cm) 2.91 inch (3.39 inch (8.62 cm) 1.0 lbs (4.45 kg) Shipping 7.32 inch (18.6 cm) 6.18 inch (15.7 cm) 3.15 inch (8.00 cm) 1.25 lbs (.57 kg) Power Input Power (powers the module) 120V AC (+/- 10%) @ 60Hz, 0.1A (max) Input Power (from external source) 240V AC @ max load power Load Power 14400VA max (240VAC 60A resistive load / 3HP max) Features of Automatic Action Type 1.B action Standards Wireless Bluetooth Low Energy (BLE) - 2.4 GHz radio frequency FCC Part 15 UL ICES 003 FCC Part 15 <t< td=""><td colspan="10">Dimensions and Weights (net)</td></t<>	Dimensions and Weights (net)									
Module		Length	Width	Height	Weight					
Power Input Power (powers the module) Input Power (from external source) Load Power Eatures of Automatic Action Standards Wireless Bluetooth Low Energy (BLE) - 2.4 GHz radio frequency Regulatory FCC Part 15 Contains FCC ID: PUU-QP1R60240 Contains IC: RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into 3/4 inch Eaton CH load centers. Supported Load Types Sarety Jerus	Module									
Input Power (powers the module) Input Power (from external source) Load Power Load Power Eatures of Automatic Action Standards Wireless Bluetooth Low Energy (BLE) - 2.4 GHz radio frequency Regulatory FCC Part 15 Contains FCC ID: PUU-QP1R60240 Contains IC: RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into 3/4 inch Eaton CH load centers. Supported Load Types Standard Configuration Electrical and Safety Characteristics Screw Tighten Torque Purpose of Control Puva AC (+/- 10%) @ 60Hz, 0.1A (max) 240V AC (e) max load power 14400VA max (240VAC 60A resistive load / 3HP max) FCC Part 15 UL ICES 003 FCC Part 15 ICES	Shipping									
Input Power (from external source) Load Power Load Power Eatures of Automatic Action Standards Wireless Bluetooth Low Energy (BLE) - 2.4 GHz radio frequency Regulatory FCC Part 15 Contains FCC ID: PUU-QP1R60240 Contains IC: RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into \(^3\)/4 inch Eaton CH load centers. Supported Load Types Standard Configuration Flectrical and Safety Copper (Cu) only Purpose of Control Puve AC (+7-10%) @ 60Hz, O.IA (max) 240V AC @ max load power 240V AC @ nax load power 240V AC @	Power									
Contains FCC ID: PUU-QPIR60240 Compliant Recommended Load Types Standard Configuration Relay On/Off type loads (home automation) Electrical and Safety Copper (Cu) only Purpose of Control Purpose of Control Operating Control, Smart Relay Control Module or the equivalent Control Control Control Control Control Copper (Cu) ontrol Control Control Copper (Cu) ontrol Control			120V AC (+/- 10%) @ 60Hz, 0.1A (max)							
Features of Automatic Action Standards Wireless Bluetooth Low Energy (BLE) - 2.4 GHz radio frequency Regulatory FCC Part 15 Contains FCC ID: PUU-QP1R60240 Contains IC: 10798A-QP1R60240 Recommended Load Center Types All Eaton CH style modules fit into ¾ inch Eaton CH load centers. Supported Load Types Standard Configuration Electrical and Safety Characteristics Screw Tighten Torque Wire Type Purpose of Control Type 1.B action FCC Part 15 UL ICES 003 FCC Part 15 FCC Part 15 UL ICES 003 FCC Part 15 FCC Part 15 UL ICES 003 FCC Part 15 FCC Part 15			240V AC @ max load power							
Automatic Action Standards Wireless Bluetooth Low Energy (BLE) - 2.4 GHz radio frequency Regulatory FCC Part 15 UL ICES 003 Contains FCC ID: PUU-QP1R60240 Contains IC: 10798A-QP1R60240 RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into ¾ inch Eaton CH load centers. Supported Load Types Standard Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent	Load Power									
Wireless Bluetooth Low Energy (BLE) - 2.4 GHz radio frequency Regulatory FCC Part 15 UL ICES 003 FCC Part 15 UL ICES 003 Contains FCC ID: PUU-QP1R60240 Contains IC: 10798A-QP1R60240 RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into ¾ inch Eaton CH load centers. Supported Load Types Standard Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent		Action	Type 1.B action							
Regulatory Safety and Emissions FCC Part 15 UL ICES 003 Contains FCC ID: PUU-QPIR60240 Contains IC: 10798A-QPIR60240 Recommended Load Center Types All Eaton CH style modules fit into 3/4 inch Eaton CH load centers. Supported Load Types Standard Configuration Relay On/Off type loads Configuration Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent	Standards									
Safety and Emissions FCC Part 15 UL ICES 003 FCC Contains FCC ID: PUU-QP1R60240 Contains IC: 10798A-QP1R60240 Recommended Load Center Types All Eaton CH style modules fit into ¾ inch Eaton CH load centers. Supported Load Types Standard Configuration Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Module or the equivalent	Wireless	-								
Contains FCC ID: PUU-QPIR60240 Contains IC: 10798A-QPIR60240 RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into ¾ inch Eaton CH load centers. Supported Load Types Standard Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent	Regulatory	,								
Contains FCC ID: PUU-QPIR60240 Contains IC: 10798A-QPIR60240 RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into ¾ inch Eaton CH load centers. Supported Load Types Standard Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent	Safety and Emissions				ICES 003					
Contains IC: 10798A-QPIR60240 RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into ¾ inch Eaton CH load centers. Supported Load Types Standard Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent				LISTED						
RoHS Compliant Recommended Load Center Types All Eaton CH style modules fit into ¾ inch Eaton CH load centers. Supported Load Types Standard Relay On/Off type loads (Configuration (home automation)) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Module or the equivalent										
Recommended Load Center Types All Eaton CH style modules fit into 3/4 inch Eaton CH load centers. Supported Load Types Standard Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent										
All Eaton CH style modules fit into 3/4 inch Eaton CH load centers. Supported Load Types Standard Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent										
Supported Load Types Standard Relay On/Off type loads Configuration (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent										
Standard Configuration Relay On/Off type loads (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent				inch Eaton CH	load centers.					
Configuration (home automation) Electrical and Safety Characteristics Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent		Load Type								
Screw Tighten Torque 5.0 Nm Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent			- · · · · · · · · · · · · · · · · · · ·							
Wire Type Copper (Cu) only Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent	Electrical a	and Safety	Characterist	ics						
Pollution Degree 2 Purpose of Control Operating Control, Smart Relay Control Module or the equivalent	Screw Tight	en Torque	5.0 Nm							
Purpose of Control Operating Control, Smart Relay Control Module or the equivalent	Wire Type	Wire Type Copper (Cu) only								
Module or the equivalent	Pollution De	gree	2							
Software Class A	Purpose of (Control								
	Software		Class A							

Descriptions



Multi-Page LCD screen that can display the following:



- Power draw at the output.
- Firmware, Mac Address, and Regulatory Info.
- UID of the Host that the module is communicating with.
- Real-time Bluetooth status connectivity icon.



Manual Load Switch - Toggle to the ON position to switch the load on. Toggle to AUTO for normal operation.

PAIR Button - The PAIR button is a multi-use button. The duration that the button is pressed and held determines the function that gets initiated:



Press and Release - Cycles through the various screens available on the LCD (POWER > INFO 1 > INFO 2).

Press and hold - Press and hold for 2 seconds to put module into pairing mode. Press and hold for 5 seconds to reset.



Input Power Connections - Connect outputs from a 2-pole breaker to inputs L1 and L2. See the Wiring section below.



Output Power Connections - Connect a 240V AC load across outputs L1 and L2. See the Wiring section below.



120V AC Connection - Plugs into the 120V AC bus bar in the breaker panel. The voltage from this connection powers the module.

Neutral - The model number of the module determines the type of neutral connection on the module:



- Plug-On Neutral Positioned on the bottom of the module is a neutral clip that plugs directly onto the neutral bar.
- Pigtail Neutral A neutral wire protrudes from the module's rear and gets wired to the neutral bar in the breaker panel.

Features

- Control capability for loads up to 14400VA (volt-ampere).
- All Eaton CH style modules are compatible with Eaton CH load centers.
- Dynamic management of loads.
- Built-in energy monitoring; +/- .5% revenue grade accuracy / 1 sec sample time.
- Communicates over the air using Bluetooth Low Energy (BLE) technology.
- Manual load switches positioned on the front panel can toggle power to the output On and Off.
- · Color LCD display for easy identification and load status.

2500V

da Vinci 10.1

Independently mounted for flush mounting

Impulse Voltage

Open Type

Savant OS

Construction of Control

Minimum Supported Release

Important Information

- The breaker feeding this relay module should not be larger than 60 amps.
- This relay module can handle loads up to 60 amps.
- To determine the number of breaker panel spaces needed, add the number of spaces required for the circuit breakers with the spaces needed for the module.
 - · A 2-pole circuit breaker requires two spaces.
 - Each 60 amp relay module requires four spaces.
- Savant recommends not connecting any mission critical loads such as medical devices to this relay module.



ELECTRIC SHOCK! The 120/240V AC, 60 Hz source poses an electrical shock hazard that has the potential to cause serious injury to installers and end users.



CAUTION! Risk of Electric Shock - More than one disconnect switch may be required to de-energize the device before servicing.



IMPORTANT! A licensed electrician is required to install any of Savant's Relay Companion Modules.

Branch Circuit Minimum Size of Conductors (General circuit wiring, Copper Conductors)									
15A	20A	30A	40A	50A	60A				
#14 AWG	#12 AWG	#10 AWG	#8 AWG	#6 AWG	#4 AWG				

NOTE: This wiring requirement was based on the National Electric Code (NEC) (ANSI/NFPA70), Canadian Electric Code, Part 1 (CEC), and local codes Minimum Size of Conductors.

Installation into Breaker Panel

- 1. Remove power from the breaker panel by switching off the panel's main breaker.
- 2. Position and install a 2-pole breaker into any two slots in the breaker panel. Press firmly until the breaker is fully seated onto the appropriate bus bars.
- 3. Position and install the 60 Amp Relay Companion Module into any four empty slots in the breaker panel. Press firmly until the module is fully seated onto the appropriate bus bar. This module can be installed in any four open slots but is typically installed alongside the breaker installed in step 2.



HELPFUL! The 60 amp relay module fills four slots in the breaker panel but connects to only one phase. The 120V AC from the breaker panel is used only to power the module. See diagrams below.


4. Use the diagrams below and make the appropriate connections. The diagram on the left is for modules that contain a plug-on neutral clip. The diagram on the right is for modules that include a neutral wire.


Wiring

Use the diagrams below for reference when making connections

Wiring with Plug-on Neutral Clip

Wiring with a Pigtail Neutral Wire





Circuit Test Instructions


Use the instructions below to test the relay modules. The setup requires:

- 60 Amp Relay Companion Module.
- Load with maximum amperage of 60A.
- Standard 2-pole, 60 amp circuit breaker.
- Breaker test panel. The type of module determines the type of breaker panel (plug-on neutral or not)
- 120/240V AC source



IMPORTANT!

- The 2-Pole breaker connects across both phases in the breaker panel. The relay module, however, attaches to only one phase. This is shown in the image below.
- The GPM-C1R60240-21 and GPM-CP1R60240-21 modules can accept up to a #4 AWG wire. See the Branch Circuit Minimum Size of Conductors table on the previous page.
- 1. Plug the 240V AC 2-Pole Companion Module and 60 amp 2-pole feeder breaker into the circuit breaker test panel.
- 2. Connect the output from one of the breakers on the 2-pole breaker to the L1 input on the module.
- 3. Connect the output from the remaining side of the 2-pole breaker to the L2 input on the module.
- 4. Connect one side of a load to the L1 output on the relay module.
- 5. Connect the remaining side of the load to the L2 output on the relay module.
- 6. On modules that contain a neutral wire, connect the neutral wire to the neutral bar.
- 7. Apply power to the breaker panel (not shown in diagram)
- 8. Toggle the 60 amp 2-pole breaker to On.
- 9. To test, toggle the CIRCUIT POWER switch to the ON position and observe the load switches On. Toggle the CIRCUIT POWER switch to AUTO and verify the load switches Off.



Additional Documentation

Further information is available in the documents listed below and can be accessed via the Savant Customer Community.

- Panel Bridge Controller PoE (PBC-P1000) QRG
- Savant Panelized Lighting Deployment Guide.

Notes