

State of California
Department of Public Health
Water Treatment Device
Certificate Number
11 - 2068

Date Issued: March 1, 2011

Trademark/Model Designation

Body Glove BG-6000FF

Replacement Elements

BG-6000FFC

Manufacturer: 3M Brand from 3M

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity

Cysts (protozoan)

Organic Contaminants

Benzene

Dichlorobenzene

Toxaphene

Inorganic/Radiological Contaminants

Lead

Rated Service Capacity: 6000 gals

Rated Service Flow: 2.5 gpm

Conditions of Certification:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.